

APPENDIX A - 2016 ANNUAL REPORT – TOWN OF ST. MARYS

Drinking-Water System Number:	220000521
Drinking-Water System Name:	St. Marys Well Supply
Drinking-Water System Owner:	The Corporation of the Town of St. Marys
Drinking-Water System Category:	Large, Municipal, Residential
Period being reported:	January 1, 2016 to December 31, 2016

<p>Does your Drinking-Water System serve more than 10,000 people? No</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <p>Municipal Operations Center, 408 James Street South</p> <p>www.townofstmarys.com</p>	<p align="center"><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: 0</p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? n/a</p> <p>Number of Interested Authorities you report to:</p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? n/a</p>
--	---

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:
n/a

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? n/a

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method - Municipal office

Describe your Drinking-Water System

Each of the pump houses #1, 2A and 3 house a vertical turbine pump, each rated at 60 L/s capacity. These draw water from all three wells. Water passes air release valves, a backflow check valve, pressure gauges, the primary UV light disinfection unit, flow meter, the chlorine gas injection point and actuator control valve and then into the contact chamber piping located underground.

List all water treatment chemicals used over this reporting period

Chlorine gas for primary and secondary disinfection

Were any significant expenses incurred to:

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred:

New Water Services on Queen Street East from Water Street to Peel Street - \$291,000
 Queen Street E Widening - \$46,000
 Glass Street Extension - \$171,000
 Variable Frequency Drive replacement for Well #2 - \$29,600.00

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
Apr. 13/16	Potential contamination – stones in main during watermain repair	Visual of stones in watermain	n/a	Flushed the area and took bacti samples	Apr. 19/16
Dec. 9/16	Low chlorine due to dead-end line at 74 Edison Street	0.00 mg/l chlorine residual	mg/l	Flushed watermain until residual of 0.50 mg/l was achieved. (approx. 15 mins)	Dec. 9/16

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli or Fecal Results (min -max) cfu/100ml	Range of Total Coliform Results (min -max) cfu/100ml	Number of HPC Samples	Range of HPC Results (min -max) cfu/1mL spread plate
Raw	151	0 - 1	0 - 44	1	1
Treated	150	0 - 0	0 - 0	150	0 - 10
Distribution	230	0 - 0	0 - 0	66	0 - 220

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results min -max	Unit of Measure
Turbidity	8760*	Well 1 0.06 - 2.00 Well 2A 0.08 - 0.13 Well 3 0.08 - 0.61	NTU
Chlorine	8760*	Well 1 0.61 - 1.56 Well 2A 0.69 - 1.92 Well 3 0.40 - 1.50	mg/L
Fluoride (If the DWS provides fluoridation)	N/A	N/A	N/A

*- continuous monitoring

Additional testing carried out in accordance with the requirement of an approval, order or other legal instrument.

Treated Water	Sample Date (mm/dd/yyyy)	Sample Result
UV Transmittance % - TW1	1/5/2016	95.0
UV Transmittance % - TW1	4/16/2016	93.7
UV Transmittance % - TW1	7/4/2016	95.1
UV Transmittance % - TW1	10/11/2016	94.4
UV Transmittance % - TW2A	1/5/2016	91.4
UV Transmittance % - TW2A	4/16/2016	94.5
UV Transmittance % - TW2A	7/4/2016	93.9
UV Transmittance % - TW2A	10/04/2016	93.6
UV Transmittance % - TW3	1/5/2016	95.8
UV Transmittance % - TW3	4/13/2016	95.5
UV Transmittance % - TW3	7/4/2016	95.7
UV Transmittance % - TW3	10/04/2016	96.1

Schedule 24 - Inorganic parameters

Treated Water	Sample Date (mm/dd/yyyy)	Sample Result	MAC	No. of Exceedances	
				MAC	1/2 MAC
Antimony: Sb (ug/L) - TW1	1/12/2016	0.02	6.0	No	No
Antimony: Sb (ug/L) - TW2A	1/12/2016	<MDL 0.02	6.0	No	No
Antimony: Sb (ug/L) - TW3	1/12/2016	0.06	6.0	No	No
Arsenic: As (ug/L) - TW1	1/12/2016	0.3	25.0	No	No

Arsenic: As (ug/L) - TW2A	1/12/2016	0.3	25.0	No	No
Arsenic: As (ug/L) - TW3	1/12/2016	<MDL 0.2	25.0	No	No
Barium: Ba (ug/L) - TW1	1/12/2016	134	1000.0	No	No
Barium: Ba (ug/L) - TW2A	1/12/2016	83.6	1000.0	No	No
Barium: Ba (ug/L) - TW3	1/12/2016	102	1000.0	No	No
Boron: B (ug/L) - TW1	1/12/2016	34.3	5000.0	No	No
Boron: B (ug/L) - TW2A	1/12/2016	45.8	5000.0	No	No
Boron: B (ug/L) - TW3	1/12/2016	47.5	5000.0	No	No
Cadmium: Cd (ug/L) - TW1	1/12/2016	0.094	5.0	No	No
Cadmium: Cd (ug/L) - TW2A	1/12/2016	0.022	5.0	No	No
Cadmium: Cd (ug/L) - TW3	1/12/2016	0.037	5.0	No	No
Chromium: Cr (ug/L) - TW1	1/12/2016	<MDL 0.03	50	No	No
Chromium: Cr (ug/L) - TW2A	1/12/2016	<MDL 0.03	50	No	No
Chromium: Cr (ug/L) - TW3	1/12/2016	<MDL 0.03	50	No	No
Mercury: Hg (ug/L) - TW1	1/12/2016	<MDL 0.01	1.0	No	No
Mercury: Hg (ug/L) - TW2A	1/12/2016	<MDL 0.01	1.0	No	No
Mercury: Hg (ug/L) - TW3	1/12/2016	0.01	1.0	No	No
Selenium: Se (ug/L) - TW1	1/12/2016	0.84	10.0	No	No
Selenium: Se (ug/L) - TW2A	1/12/2016	0.51	10.0	No	No
Selenium: Se (ug/L) - TW3	1/12/2016	0.62	10.0	No	No
Uranium: U (ug/L) - TW1	1/12/2016	1.30	20.0	No	No
Uranium: U (ug/L) - TW2A	1/12/2016	1.82	20.0	No	No
Uranium: U (ug/L) - TW3	1/12/2016	2.47	20.0	No	No
Additional Inorganics					
Fluoride (mg/L) - TW1	1/21/2015	0.97	1.5	No	No
Fluoride (mg/L) - TW2A	1/21/2015	1.23	1.5	No	No
Fluoride (mg/L) - TW3	1/21/2015	1.14	1.5	No	No
Nitrite (mg/L) - TW1	1/5/2016	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW1	4/13/2016	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW1	7/4/2016	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW1	10/11/2016	<MDL 0.003	1.0	No	No

Nitrite (mg/L) - TW2A	1/5/2016	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW2A	4/16/2016	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW2A	7/4/2016	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW2A	10/4/2016	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW3	1/5/2016	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW3	4/13/2016	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW3	7/4/2016	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW3	10/4/2016	0.004	1.0	No	No
Nitrate (mg/L) - TW1	1/5/2016	1.59	10.0	No	No
Nitrate (mg/L) - TW1	4/13/2016	3.72	10.0	No	No
Nitrate (mg/L) - TW1	7/4/2016	0.992	10.0	No	No
Nitrate (mg/L) - TW1	10/11/2016	0.49	10.0	No	No
Nitrate (mg/L) - TW2A	1/5/2016	0.402	10.0	No	No
Nitrate (mg/L) - TW2A	4/16/2016	1.25	10.0	No	No
Nitrate (mg/L) - TW2A	7/4/2016	0.633	10.0	No	No
Nitrate (mg/L) - TW2A	10/4/2016	0.348	10.0	No	No
Nitrate (mg/L) - TW3	1/5/2016	0.408	10.0	No	No
Nitrate (mg/L) - TW3	4/13/2016	1.02	10.0	No	No
Nitrate (mg/L) - TW3	7/4/2016	0.616	10.0	No	No
Nitrate (mg/L) - TW3	10/4/2016	0.265	10.0	No	No
Sodium: Na (mg/L) - TW1	1/21/2015	33.6	20*	Yes	Yes
Sodium: Na (mg/L) - TW2A	1/21/2015	61.1	20*	Yes	Yes
Sodium: Na (mg/L) - TW3	1/21/2015	50.6	20*	Yes	Yes

Summary of lead testing under Schedule 15.1 during this reporting period

Location Type	Date Sampled	Number of Samples	pH Range	Range of Alkalinity (min - max) mg/L	Range of Lead Results (min - max) ug/L	Number of Exceedances
Distribution	Feb. and August 2016	6	6.55 - 7.25	256 - 279	0.25 - 1.57	0

Schedule 23 - Organic parameters

Treated Water	Sample Date (mm/dd/yyyy)	Sample Result	MAC	Number of Exceedances	
				MAC	1/2 MAC
Alachlor (ug/L) - TW1	1/12/2016	<MDL 0.02	5.00	No	No
Alachlor (ug/L) - TW2A	1/12/2016	<MDL 0.02	5.00	No	No
Alachlor (ug/L) - TW3	1/12/2016	<MDL 0.02	5.00	No	No
Atrazine + N-dealkylated metabolites (ug/L) - TW1	1/12/2016	0.03	5.00	No	No
Atrazine + N-dealkylated metabolites (ug/L) - TW2A	1/12/2016	<MDL 0.01	5.00	No	No
Atrazine + N-dealkylated metabolites (ug/L) - TW3	1/12/2016	<MDL 0.01	5.00	No	No
Azinphos-methyl (ug/L) - TW1	1/12/2016	<MDL 0.05	20.00	No	No
Azinphos-methyl (ug/L) - TW2A	1/12/2016	<MDL 0.05	20.00	No	No
Azinphos-methyl (ug/L) - TW3	1/12/2016	<MDL 0.05	20.00	No	No
Benzene (ug/L) - TW1	1/12/2016	<MDL 0.32	5.00	No	No
Benzene (ug/L) - TW2A	1/12/2016	<MDL 0.32	5.00	No	No
Benzene (ug/L) - TW3	1/12/2016	<MDL 0.32	5.00	No	No
Benzo(a)pyrene (ug/L) - TW1	1/12/2016	<MDL 0.004	0.01	No	No
Benzo(a)pyrene (ug/L) - TW2A	1/12/2016	<MDL 0.004	0.01	No	No
Benzo(a)pyrene (ug/L) - TW3	1/12/2016	<MDL 0.004	0.01	No	No
Bromoxynil (ug/L) - TW1	1/12/2016	<MDL 0.33	5.00	No	No
Bromoxynil (ug/L) - TW2A	1/12/2016	<MDL 0.33	5.00	No	No
Bromoxynil (ug/L) - TW3	1/12/2016	<MDL 0.33	5.00	No	No
Carbaryl (ug/L) - TW1	1/12/2016	<MDL 0.05	90.00	No	No
Carbaryl (ug/L) - TW2A	1/12/2016	<MDL 0.05	90.00	No	No
Carbaryl (ug/L) - TW3	1/12/2016	<MDL 0.05	90.00	No	No
Carbofuran (ug/L) - TW1	1/12/2016	<MDL 0.01	90.00	No	No
Carbofuran (ug/L) - TW2A	1/12/2016	<MDL 0.01	90.00	No	No
Carbofuran (ug/L) - TW3	1/12/2016	<MDL 0.01	90.00	No	No
Carbon Tetrachloride (ug/L) - TW1	1/12/2016	<MDL 0.16	5.00	No	No

Carbon Tetrachloride (ug/L) - TW2A	1/12/2016	<MDL 0.16	5.00	No	No
Carbon Tetrachloride (ug/L) - TW3	1/12/2016	<MDL 0.16	5.00	No	No
Chlorpyrifos (ug/L) - TW1	1/12/2016	<MDL 0.02	90.00	No	No
Chlorpyrifos (ug/L) - TW2A	1/12/2016	<MDL 0.02	90.00	No	No
Chlorpyrifos (ug/L) - TW3	1/12/2016	<MDL 0.02	90.00	No	No
Diazinon (ug/L) - TW1	1/12/2016	<MDL 0.02	20.00	No	No
Diazinon (ug/L) - TW2A	1/12/2016	<MDL 0.02	20.00	No	No
Diazinon (ug/L) - TW3	1/12/2016	<MDL 0.02	20.00	No	No
Dicamba (ug/L) - TW1	1/12/2016	<MDL 0.20	120.00	No	No
Dicamba (ug/L) - TW2A	1/12/2016	<MDL 0.20	120.00	No	No
Dicamba (ug/L) - TW3	1/12/2016	<MDL 0.20	120.00	No	No
1,2-Dichlorobenzene (ug/L) - TW1	1/12/2016	<MDL 0.41	200.00	No	No
1,2-Dichlorobenzene (ug/L) - TW2A	1/12/2016	<MDL 0.41	200.00	No	No
1,2-Dichlorobenzene (ug/L) - TW3	1/12/2016	<MDL 0.41	200.00	No	No
1,4-Dichlorobenzene (ug/L) - TW1	1/12/2016	<MDL 0.36	5.00	No	No
1,4-Dichlorobenzene (ug/L) - TW2A	1/12/2016	<MDL 0.36	5.00	No	No
1,4-Dichlorobenzene (ug/L) - TW3	1/12/2016	<MDL 0.36	5.00	No	No
1,2-Dichloroethane (ug/L) - TW1	1/12/2016	<MDL 0.35	5.00	No	No
1,2-Dichloroethane (ug/L) - TW2A	1/12/2016	<MDL 0.35	5.00	No	No
1,2-Dichloroethane (ug/L) - TW3	1/12/2016	<MDL 0.35	5.00	No	No
1,1-Dichloroethylene (ug/L) - TW1	1/12/2016	<MDL 0.33	14.00	No	No
1,1-Dichloroethylene (ug/L) - TW2A	1/12/2016	<MDL 0.33	14.00	No	No
1,1-Dichloroethylene (ug/L) - TW3	1/12/2016	<MDL 0.33	14.00	No	No
Dichloromethane (Methylene Chloride) (ug/L) - TW1	1/12/2016	<MDL 0.35	50.00	No	No
Dichloromethane (Methylene Chloride) (ug/L) - TW2A	1/12/2016	<MDL 0.35	50.00	No	No
Dichloromethane (Methylene Chloride) (ug/L) - TW3	1/12/2016	<MDL 0.35	50.00	No	No
2,4-Dichlorophenol (ug/L) - TW1	1/12/2016	<MDL 0.15	900.00	No	No
2,4-Dichlorophenol (ug/L) - TW2A	1/12/2016	<MDL 0.15	900.00	No	No
2,4-Dichlorophenol (ug/L) - TW3	1/12/2016	<MDL 0.15	900.00	No	No

2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW1	1/12/2016	<MDL 0.19	100.00	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW2A	1/12/2016	<MDL 0.19	100.00	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW3	1/12/2016	<MDL 0.19	100.00	No	No
Diclofop-methyl (ug/L) - TW1	1/12/2016	<MDL 0.40	9.00	No	No
Diclofop-methyl (ug/L) - TW2A	1/12/2016	<MDL 0.40	9.00	No	No
Diclofop-methyl (ug/L) - TW3	1/12/2016	<MDL 0.40	9.00	No	No
Dimethoate (ug/L) - TW1	1/12/2016	<MDL 0.03	20.00	No	No
Dimethoate (ug/L) - TW2A	1/12/2016	<MDL 0.03	20.00	No	No
Dimethoate (ug/L) - TW3	1/12/2016	<MDL 0.03	20.00	No	No
Diquat (ug/L) - TW1	1/12/2016	<MDL 1	70.00	No	No
Diquat (ug/L) - TW2A	1/12/2016	<MDL 1	70.00	No	No
Diquat (ug/L) - TW3	1/12/2016	<MDL 1	70.00	No	No
Diuron (ug/L) - TW1	1/12/2016	<MDL 0.03	150.00	No	No
Diuron (ug/L) - TW2A	1/12/2016	<MDL 0.03	150.00	No	No
Diuron (ug/L) - TW3	1/12/2016	<MDL 0.03	150.00	No	No
Glyphosate (ug/L) - TW1	1/12/2016	<MDL 1	280.00	No	No
Glyphosate (ug/L) - TW2A	1/12/2016	<MDL 1	280.00	No	No
Glyphosate (ug/L) - TW3	1/12/2016	<MDL 1	280.00	No	No
Malathion (ug/L) - TW1	1/12/2016	<MDL 0.02	190.00	No	No
Malathion (ug/L) - TW2A	1/12/2016	<MDL 0.02	190.00	No	No
Malathion (ug/L) - TW3	1/12/2016	<MDL 0.02	190.00	No	No
2-Methyl-4-chlorophenoxyacetic acid MCPA (mg/L) - TW1	1/12/2016	<MDL 0.00012	0.10	No	No
2-Methyl-4-chlorophenoxyacetic acid MCPA (mg/L) - TW2A	1/12/2016	<MDL 0.00012	0.10	No	No
2-Methyl-4-chlorophenoxyacetic acid MCPA (mg/L) - TW3	1/12/2016	<MDL 0.00012	0.10	No	No
Metolachlor (ug/L) - TW1	1/12/2016	<MDL 0.01	50.00	No	No
Metolachlor (ug/L) - TW2A	1/12/2016	<MDL 0.01	50.00	No	No
Metolachlor (ug/L) - TW3	1/12/2016	<MDL 0.01	50.00	No	No
Metribuzin (ug/L) - TW1	1/12/2016	<MDL 0.02	80.00	No	No

Metribuzin (ug/L) - TW2A	1/12/2016	<MDL 0.02	80.00	No	No
Metribuzin (ug/L) - TW3	1/12/2016	<MDL 0.02	80.00	No	No
Monochlorobenzene (Chlorobenzene) (ug/L) - TW1	1/12/2016	<MDL 0.3	80.00	No	No
Monochlorobenzene (Chlorobenzene) (ug/L) - TW2A	1/12/2016	<MDL 0.3	80.00	No	No
Monochlorobenzene (Chlorobenzene) (ug/L) - TW3	1/12/2016	<MDL 0.3	80.00	No	No
Paraquat (ug/L) - TW1	1/12/2016	<MDL 1	10.00	No	No
Paraquat (ug/L) - TW2A	1/12/2016	<MDL 1	10.00	No	No
Paraquat (ug/L) - TW3	1/12/2016	<MDL 1	10.00	No	No
PCB (ug/L) - TW1	1/12/2016	<MDL 0.04	3.00	No	No
PCB (ug/L) - TW2A	1/12/2016	<MDL 0.04	3.00	No	No
PCB (ug/L) - TW3	1/12/2016	<MDL 0.04	3.00	No	No
Pentachlorophenol (ug/L) - TW1	1/12/2016	<MDL 0.15	60.00	No	No
Pentachlorophenol (ug/L) - TW2A	1/12/2016	<MDL 0.15	60.00	No	No
Pentachlorophenol (ug/L) - TW3	1/12/2016	<MDL 0.15	60.00	No	No
Phorate (ug/L) - TW1	1/12/2016	<MDL 0.01	2.00	No	No
Phorate (ug/L) - TW2A	1/12/2016	<MDL 0.01	2.00	No	No
Phorate (ug/L) - TW3	1/12/2016	<MDL 0.01	2.00	No	No
Picloram (ug/L) - TW1	1/12/2016	<MDL 1	190.00	No	No
Picloram (ug/L) - TW2A	1/12/2016	<MDL 1	190.00	No	No
Picloram (ug/L) - TW3	1/12/2016	<MDL 1	190.00	No	No
Prometryne (ug/L) - TW1	1/12/2016	<MDL 0.03	1.00	No	No
Prometryne (ug/L) - TW2A	1/12/2016	<MDL 0.03	1.00	No	No
Prometryne (ug/L) - TW3	1/12/2016	<MDL 0.03	1.00	No	No
Simazine (ug/L) - TW1	1/12/2016	<MDL 0.01	10.00	No	No
Simazine (ug/L) - TW2A	1/12/2016	<MDL 0.01	10.00	No	No
Simazine (ug/L) - TW3	1/12/2016	<MDL 0.01	10.00	No	No
Terbufos (ug/L) - TW1	1/12/2016	<MDL 0.01	1.00	No	No
Terbufos (ug/L) - TW2A	1/12/2016	<MDL 0.01	1.00	No	No
Terbufos (ug/L) - TW3	1/12/2016	<MDL 0.01	1.00	No	No

Tetrachloroethylene (ug/L) - TW1	1/12/2016	<MDL 0.35	30.00	No	No
Tetrachloroethylene (ug/L) - TW2A	1/12/2016	<MDL 0.35	30.00	No	No
Tetrachloroethylene (ug/L) - TW3	1/12/2016	<MDL 0.35	30.00	No	No
2,3,4,6-Tetrachlorophenol (ug/L) - TW1	1/12/2016	<MDL 0.20	100.00	No	No
2,3,4,6-Tetrachlorophenol (ug/L) - TW2A	1/12/2016	<MDL 0.20	100.00	No	No
2,3,4,6-Tetrachlorophenol (ug/L) - TW3	1/12/2016	<MDL 0.20	100.00	No	No
Triallate (ug/L) - TW1	1/12/2016	<MDL 0.01	230.00	No	No
Triallate (ug/L) - TW2A	1/12/2016	<MDL 0.01	230.00	No	No
Triallate (ug/L) - TW3	1/12/2016	<MDL 0.01	230.00	No	No
Trichloroethylene (ug/L) - TW1	1/12/2016	<MDL 0.44	50.00	No	No
Trichloroethylene (ug/L) - TW2A	1/12/2016	<MDL 0.44	50.00	No	No
Trichloroethylene (ug/L) - TW3	1/12/2016	<MDL 0.44	50.00	No	No
2,4,6-Trichlorophenol (ug/L) - TW1	1/12/2016	<MDL 0.25	5.00	No	No
2,4,6-Trichlorophenol (ug/L) - TW2A	1/12/2016	<MDL 0.25	5.00	No	No
2,4,6-Trichlorophenol (ug/L) - TW3	1/12/2016	<MDL 0.25	5.00	No	No
Trifluralin (ug/L) - TW1	1/12/2016	<MDL 0.02	45.00	No	No
Trifluralin (ug/L) - TW2A	1/12/2016	<MDL 0.02	45.00	No	No
Trifluralin (ug/L) - TW3	1/12/2016	<MDL 0.02	45.00	No	No
Vinyl Chloride (ug/L) - TW1	1/12/2016	<MDL 0.17	2.00	No	No
Vinyl Chloride (ug/L) - TW2A	1/12/2016	<MDL 0.17	2.00	No	No
Vinyl Chlorine (ug/L) - TW3	1/12/2016	<MDL 0.17	2.00	No	No
Trihalomethanes - farthest point in the distribution system (ug/L)	Running average	20.75	100	No	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards. n/a