

**2018 ANNUAL REPORT – TOWN OF ST. MARYS**

<b>Drinking-Water System Number:</b>	<b>220000521</b>
<b>Drinking-Water System Name:</b>	St. Marys Well Supply
<b>Drinking-Water System Owner:</b>	The Corporation of the Town of St. Marys
<b>Drinking-Water System Category:</b>	Large, Municipal, Residential
<b>Period being reported:</b>	January 1, 2018 to December 31, 2018

<p><b>Does your Drinking-Water System serve more than 10,000 people? No</b></p> <p><b>Is your annual report available to the public at no charge on a web site on the Internet? Yes</b></p> <p><b>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</b></p> <p><b>Municipal Operations Center, 408 James Street South www.townofstmarys.com</b></p>	<p><b>Number of Designated Facilities served: 0</b></p> <p><b>Did you provide a copy of your annual report to all Designated Facilities you serve? n/a</b></p> <p><b>Number of Interested Authorities you report to: 0</b></p> <p><b>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? n/a</b></p>
---	---

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:  
n/a

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? n/a

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Public Request
- Public access/notice via other method - Municipal office

**Drinking-Water System**

Each of the pump houses #1, 2A and 3 house a vertical turbine pump, each rated at 60 L/s capacity. These draw ground water from all three wells. Water passes air release valves, a backflow check valve, pressure gauges, primary UV light disinfection, flow meter, the chlorine gas injection point and actuator control valve and then into the contact chamber piping located underground.

**Booster Station**

This provides additional system pressure for industrial properties within the southeast area of the town during fire emergencies.

**Water Tower**

The water tower is for system pressure regulation and has a storage capacity of 1,820 m3.

**Water Treatment Chemicals**

Chlorine gas for primary and secondary disinfection

**Expenses to install, repair or replace equipment**

Well #3 - VFD replacement - \$8,285.00

Well #2A - Turbidity meter repairs - \$1,750.00

Well #3 - HMI replacement for UV system - Well #3 - \$4,570.00

Well #3 - Replacement fan for UV system - \$1,319.00

Well #2A - well pump rehabilitation: \$38,000

Church St. and Station St. hydrant replacement hydrant repair \$2817.00

10" valve replacements on Widder St. E and King St. N and 6" valve replacement at Widder St. E. and Church St. N - \$5,000

James St. Skate Park valve replacement and hydrant removal at Skate Park - \$1,943.00

New Reservoir and Booster Pumping Station: \$3,000,000

Generator installation at Booster Station - \$120,000

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre.**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
No adverse for 2018 reporting period					

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03**

	Number of Samples	Range of E.Coli or Fecal Results (min -max) cfu/100ml	Range of Total Coliform Results (min -max) cfu/100ml	Number of HPC Samples	Range of HPC Results (min -max) cfu/1mL spread plate
<b>Raw</b>	152	0 - 1	0 - 32	-	-
<b>Treated</b>	152	0 - 0	0 - 0	152	0 - <10
<b>Distribution</b>	203	0 - 0	0 - 0	50	0 - <10

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	Number of Grab Samples	Range of Results min -max	Unit of Measure
<b>Turbidity</b>	8760*	Well 1 0.20 - 2.00 Well 2A 0.02 - 1.96 Well 3 0.13 - 2.00	NTU
<b>Chlorine</b>	8760*	Well 1 0.74- 1.65 Well 2A 0.43 - 1.67 Well 3 0.50 - 2.20	mg/L
<b>Fluoride</b> (If the DWS provides fluoridation)	N/A	N/A	N/A

\*- continuous monitoring

The 2017 Annual report has been completed based on the information we have in our records and in accordance with section

11(1) O. Reg. 170/03 under the Safe Drinking Water Act which requires an Annual Report to be prepared not later than February

28<sup>th</sup> of each year for the preceding calendar year. This report covers the period of January 1, 2017 to December 31, 2017.

The annual report is not required to be submitted to the Ministry of Environment however it is still required to be completed

**and available to the public by the February 28<sup>th</sup> of each year. Additional testing carried out in accordance with the requirement of an approval, order or other legal instrument.**

Treated Water	Sample Date (mm/dd/yyyy)	Sample Result
UV Transmittance % - TW1	1/09/2018	94.3
UV Transmittance % - TW1	4/10/2018	93.9
UV Transmittance % - TW1	7/06/2018	94.1
UV Transmittance % - TW1	10/02/2018	94.4
UV Transmittance % - TW2A	1/09/2018	91.7
UV Transmittance % - TW2A	4/11/2018	93.8
UV Transmittance % - TW2A	7/06/2018	93.3
UV Transmittance % - TW2A	10/02/2018	94.0
UV Transmittance % - TW3	1/09/2018	94.9
UV Transmittance % - TW3	4/11/2018	95.5
UV Transmittance % - TW3	7/06/2018	95.3
UV Transmittance % - TW3	10/02/2018	95.0

**Schedule 24 - Inorganic parameters**

Treated Water	Sample Date (mm/dd/yyyy)	Sample Result	MAC	No. of Exceedances	
				MAC	1/2 MAC
Antimony: Sb (ug/L) - TW1	1/09/2018	0.14	6.0	No	No
Antimony: Sb (ug/L) - TW2A	1/09/2018	0.08	6.0	No	No
Antimony: Sb (ug/L) - TW3	1/09/2018	0.34	6.0	No	No
Arsenic: As (ug/L) - TW1	1/09/2018	0.3	25.0	No	No
Arsenic: As (ug/L) - TW2A	1/09/2018	0.5	25.0	No	No
Arsenic: As (ug/L) - TW3	1/09/2018	0.2	25.0	No	No
Barium: Ba (ug/L) - TW1	1/09/2018	153	1000	No	No
Barium: Ba (ug/L) - TW2A	1/09/2018	105	1000	No	No
Barium: Ba (ug/L) - TW3	1/09/2018	114	1000	No	No

Boron: B (ug/L) - TW1	1/09/2018	48	5000	No	No
Boron: B (ug/L) - TW2A	1/09/2018	53	5000	No	No
Boron: B (ug/L) - TW3	1/09/2018	58	5000	No	No
Cadmium: Cd (ug/L) - TW1	1/09/2018	0.118	5.0	No	No
Cadmium: Cd (ug/L) - TW2A	1/09/2018	0.032	5.0	No	No
Cadmium: Cd (ug/L) - TW3	1/09/2018	0.041	5.0	No	No
Chromium: Cr (ug/L) - TW1	1/09/2018	0.10	50	No	No
Chromium: Cr (ug/L) - TW2A	1/09/2018	0.25	50	No	No
Chromium: Cr (ug/L) - TW3	1/09/2018	0.11	50	No	No
Mercury: Hg (ug/L) - TW1	1/09/2018	0.03	1.0	No	No
Mercury: Hg (ug/L) - TW2A	1/09/2018	0.02	1.0	No	No
Mercury: Hg (ug/L) - TW3	1/09/2018	0.02	1.0	No	No
Selenium: Se (ug/L) - TW1	1/09/2018	0.84	50.0	No	No
Selenium: Se (ug/L) - TW2A	1/09/2018	0.50	50.0	No	No
Selenium: Se (ug/L) - TW3	1/09/2018	0.82	50.0	No	No
Uranium: U (ug/L) - TW1	1/09/2018	1.42	20.0	No	No
Uranium: U (ug/L) - TW2A	1/09/2018	2.03	20.0	No	No
Uranium: U (ug/L) - TW3	1/09/2018	2.99	20.0	No	No
<b>Additional Inorganics</b>					
Fluoride (mg/L) - TW1	1/09/2018	1.13	1.5	No	No
Fluoride (mg/L) - TW2A	1/09/2018	1.23	1.5	No	No
Fluoride (mg/L) - TW3	1/09/2018	1.00	1.5	No	No
Nitrite (mg/L) - TW1	1/09/2018	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW1	4/10/2018	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW1	7/11/2018	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW1	10/02/2018	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW2A	1/09/2018	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW2A	4/11/2018	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW2A	7/06/2018	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW2A	10/02/2018	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW3	1/09/2018	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW3	4/11/2018	<MDL 0.003	1.0	No	No

Nitrite (mg/L) - TW3	7/06/2018	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW3	10/02/2018	0.009	1.0	No	No
Nitrate (mg/L) - TW1	1/09/2018	1.47	10.0	No	No
Nitrate (mg/L) - TW1	4/10/2018	3.05	10.0	No	No
Nitrate (mg/L) - TW1	7/06/2018	2.32	10.0	No	No
Nitrate (mg/L) - TW1	10/02/2018	1.05	10.0	No	No
Nitrate (mg/L) - TW2A	1/09/2018	0.634	10.0	No	No
Nitrate (mg/L) - TW2A	4/11/2018	1.22	10.0	No	No
Nitrate (mg/L) - TW2A	7/06/2018	1.06	10.0	No	No
Nitrate (mg/L) - TW2A	10/02/2018	0.647	10.0	No	No
Nitrate (mg/L) - TW3	1/09/2018	0.526	10.0	No	No
Nitrate (mg/L) - TW3	4/11/2018	0.867	10.0	No	No
Nitrate (mg/L) - TW3	7/06/2018	0.872	10.0	No	No
Nitrate (mg/L) - TW3	10/02/2018	0.593	10.0	No	No
Sodium: Na (mg/L) - TW1	1/09/2018	28.6	20*	Yes*	Yes
Sodium: Na (mg/L) - TW2A	1/09/2018	51.6	20*	Yes*	Yes
Sodium: Na (mg/L) - TW3	1/09/2018	61.5	20*	Yes*	Yes

\*Adverse for Sodium last reported on January 26, 2015 – report required every 5 years

**Summary of lead testing under Schedule 15.1 during this reporting period**

Location Type	Date Sampled	Number of Samples	pH Range	Range of Alkalinity (min – max) mg/L	Range of Lead Results (min – max) ug/L	Number of Exceedances
Distribution	March and August	6	7.42 – 7.82	239 – 280	0.23 – 2.02	0

**Schedule 23 – Organic parameters**

Treated Water	Sample Date (mm/dd/yyyy)	Sample Result	MAC	Number of Exceedances	
				MAC	1/2 MAC
Alachlor (ug/L) - TW1	1/09/2018	<MDL 0.02	5.00	No	No
Alachlor (ug/L) - TW2A	1/09/2018	<MDL 0.02	5.00	No	No
Alachlor (ug/L) - TW3	1/09/2018	<MDL 0.02	5.00	No	No
Atrazine + N-dealkylated metabolites (ug/L) - TW1	1/09/2018	<MDL 0.02	5.00	No	No
Atrazine + N-dealkylated metabolites (ug/L) - TW2A	1/09/2018	<MDL 0.02	5.00	No	No

Atrazine + N-dealkylated metabolites (ug/L) - TW3	1/09/2018	<MDL 0.02	5.00	No	No
Azinphos-methyl (ug/L) - TW1	1/09/2018	<MDL 0.05	20.00	No	No
Azinphos-methyl (ug/L) - TW2A	1/09/2018	<MDL 0.05	20.00	No	No
Azinphos-methyl (ug/L) - TW3	1/09/2018	<MDL 0.05	20.00	No	No
Benzene (ug/L) - TW1	1/09/2018	<MDL 0.32	5.00	No	No
Benzene (ug/L) - TW2A	1/09/2018	<MDL 0.32	5.00	No	No
Benzene (ug/L) - TW3	1/09/2018	<MDL 0.32	5.00	No	No
Benzo(a)pyrene (ug/L) - TW1	1/09/2018	<MDL 0.004	0.01	No	No
Benzo(a)pyrene (ug/L) - TW2A	1/09/2018	<MDL 0.004	0.01	No	No
Benzo(a)pyrene (ug/L) - TW3	1/09/2018	<MDL 0.004	0.01	No	No
Bromoxynil (ug/L) - TW1	1/09/2018	<MDL 0.33	5.00	No	No
Bromoxynil (ug/L) - TW2A	1/09/2018	<MDL 0.33	5.00	No	No
Bromoxynil (ug/L) - TW3	1/09/2018	<MDL 0.33	5.00	No	No
Carbaryl (ug/L) - TW1	1/09/2018	<MDL 0.05	90.00	No	No
Carbaryl (ug/L) - TW2A	1/09/2018	<MDL 0.05	90.00	No	No
Carbaryl (ug/L) - TW3	1/09/2018	<MDL 0.05	90.00	No	No
Carbofuran (ug/L) - TW1	1/09/2018	<MDL 0.01	90.00	No	No
Carbofuran (ug/L) - TW2A	1/09/2018	<MDL 0.01	90.00	No	No
Carbofuran (ug/L) - TW3	1/09/2018	<MDL 0.01	90.00	No	No
Carbon Tetrachloride (ug/L) - TW1	1/09/2018	<MDL 0.16	5.00	No	No
Carbon Tetrachloride (ug/L) - TW2A	1/09/2018	<MDL 0.16	5.00	No	No
Carbon Tetrachloride (ug/L) - TW3	1/09/2018	<MDL 0.16	5.00	No	No
Chlorpyrifos (ug/L) - TW1	1/09/2018	<MDL 0.02	90.00	No	No
Chlorpyrifos (ug/L) - TW2A	1/09/2018	<MDL 0.02	90.00	No	No
Chlorpyrifos (ug/L) - TW3	1/09/2018	<MDL 0.02	90.00	No	No
Diazinon (ug/L) - TW1	1/09/2018	<MDL 0.02	20.00	No	No
Diazinon (ug/L) - TW2A	1/09/2018	<MDL 0.02	20.00	No	No
Diazinon (ug/L) - TW3	1/09/2018	<MDL 0.02	20.00	No	No
Dicamba (ug/L) - TW1	1/09/2018	<MDL 0.20	120.00	No	No
Dicamba (ug/L) - TW2A	1/09/2018	<MDL 0.20	120.00	No	No

Dicamba (ug/L) - TW3	1/09/2018	<MDL 0.20	120.00	No	No
1,2-Dichlorobenzene (ug/L) - TW1	1/09/2018	<MDL 0.41	200.00	No	No
1,2-Dichlorobenzene (ug/L) - TW2A	1/09/2018	<MDL 0.41	200.00	No	No
1,2-Dichlorobenzene (ug/L) - TW3	1/09/2018	<MDL 0.41	200.00	No	No
1,4-Dichlorobenzene (ug/L) - TW1	1/09/2018	<MDL 0.36	5.00	No	No
1,4-Dichlorobenzene (ug/L) - TW2A	1/09/2018	<MDL 0.36	5.00	No	No
1,4-Dichlorobenzene (ug/L) - TW3	1/09/2018	<MDL 0.36	5.00	No	No
1,2-Dichloroethane (ug/L) - TW1	1/09/2018	<MDL 0.35	5.00	No	No
1,2-Dichloroethane (ug/L) - TW2A	1/09/2018	<MDL 0.35	5.00	No	No
1,2-Dichloroethane (ug/L) - TW3	1/09/2018	<MDL 0.35	5.00	No	No
1,1-Dichloroethylene (ug/L) - TW1	1/09/2018	<MDL 0.33	14.00	No	No
1,1-Dichloroethylene (ug/L) - TW2A	1/09/2018	<MDL 0.33	14.00	No	No
1,1-Dichloroethylene (ug/L) - TW3	1/09/2018	<MDL 0.33	14.00	No	No
Dichloromethane (Methylene Chloride) (ug/L) - TW1	1/09/2018	<MDL 0.35	50.00	No	No
Dichloromethane (Methylene Chloride) (ug/L) - TW2A	1/09/2018	<MDL 0.35	50.00	No	No
Dichloromethane (Methylene Chloride) (ug/L) - TW3	1/09/2018	<MDL 0.35	50.00	No	No
2,4-Dichlorophenol (ug/L) - TW1	1/09/2018	<MDL 0.15	900.00	No	No
2,4-Dichlorophenol (ug/L) - TW2A	1/09/2018	<MDL 0.15	900.00	No	No
2,4-Dichlorophenol (ug/L) - TW3	1/09/2018	<MDL 0.15	900.00	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW1	1/09/2018	<MDL 0.19	100.00	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW2A	1/09/2018	<MDL 0.19	100.00	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW3	1/09/2018	<MDL 0.19	100.00	No	No
Diclofop-methyl (ug/L) - TW1	1/09/2018	<MDL 0.40	9.00	No	No
Diclofop-methyl (ug/L) - TW2A	1/09/2018	<MDL 0.40	9.00	No	No
Diclofop-methyl (ug/L) - TW3	1/09/2018	<MDL 0.40	9.00	No	No
Dimethoate (ug/L) - TW1	1/09/2018	<MDL 0.03	20.00	No	No
Dimethoate (ug/L) - TW2A	1/09/2018	<MDL 0.03	20.00	No	No
Dimethoate (ug/L) - TW3	1/09/2018	<MDL 0.03	20.00	No	No

Diquat (ug/L) - TW1	1/09/2018	<MDL 1	70.00	No	No
Diquat (ug/L) - TW2A	1/09/2018	<MDL 1	70.00	No	No
Diquat (ug/L) - TW3	1/09/2018	<MDL 1	70.00	No	No
Diuron (ug/L) - TW1	1/09/2018	<MDL 0.03	150.00	No	No
Diuron (ug/L) - TW2A	1/09/2018	<MDL 0.03	150.00	No	No
Diuron (ug/L) - TW3	1/09/2018	<MDL 0.03	150.00	No	No
Glyphosate (ug/L) - TW1	1/09/2018	<MDL 1	280.00	No	No
Glyphosate (ug/L) - TW2A	1/09/2018	<MDL 1	280.00	No	No
Glyphosate (ug/L) - TW3	1/09/2018	<MDL 1	280.00	No	No
Malathion (ug/L) - TW1	1/09/2018	<MDL 0.02	190.00	No	No
Malathion (ug/L) - TW2A	1/09/2018	<MDL 0.02	190.00	No	No
Malathion (ug/L) - TW3	1/09/2018	<MDL 0.02	190.00	No	No
2-Methyl-4-chlorophenoxyacetic acid MCPA (mg/L) - TW1	1/09/2018	<MDL 0.00012	0.10	No	No
2-Methyl-4-chlorophenoxyacetic acid MCPA (mg/L) - TW2A	1/09/2018	<MDL 0.00012	0.10	No	No
2-Methyl-4-chlorophenoxyacetic acid MCPA (mg/L) - TW3	1/09/2018	<MDL 0.00012	0.10	No	No
Metolachlor (ug/L) - TW1	1/09/2018	<MDL 0.01	50.00	No	No
Metolachlor (ug/L) - TW2A	1/09/2018	<MDL 0.01	50.00	No	No
Metolachlor (ug/L) - TW3	1/09/2018	<MDL 0.01	50.00	No	No
Metribuzin (ug/L) - TW1	1/09/2018	<MDL 0.02	80.00	No	No
Metribuzin (ug/L) - TW2A	1/09/2018	<MDL 0.02	80.00	No	No
Metribuzin (ug/L) - TW3	1/09/2018	<MDL 0.02	80.00	No	No
Monochlorobenzene (Chlorobenzene) (ug/L) - TW1	1/09/2018	<MDL 0.3	80.00	No	No
Monochlorobenzene (Chlorobenzene) (ug/L) - TW2A	1/09/2018	<MDL 0.3	80.00	No	No
Monochlorobenzene (Chlorobenzene) (ug/L) - TW3	1/09/2018	<MDL 0.3	80.00	No	No
Paraquat (ug/L) - TW1	1/09/2018	<MDL 1	10.00	No	No
Paraquat (ug/L) - TW2A	1/09/2018	<MDL 1	10.00	No	No
Paraquat (ug/L) - TW3	1/09/2018	<MDL 1	10.00	No	No



PCB (ug/L) - TW1	1/09/2018	<MDL 0.04	3.00	No	No
PCB (ug/L) - TW2A	1/09/2018	<MDL 0.04	3.00	No	No
PCB (ug/L) - TW3	1/09/2018	<MDL 0.04	3.00	No	No
Pentachlorophenol (ug/L) - TW1	1/09/2018	<MDL 0.15	60.00	No	No
Pentachlorophenol (ug/L) - TW2A	1/09/2018	<MDL 0.15	60.00	No	No
Pentachlorophenol (ug/L) - TW3	1/09/2018	<MDL 0.15	60.00	No	No
Phorate (ug/L) - TW1	1/09/2018	<MDL 0.01	2.00	No	No
Phorate (ug/L) - TW2A	1/09/2018	<MDL 0.01	2.00	No	No
Phorate (ug/L) - TW3	1/09/2018	<MDL 0.01	2.00	No	No
Picloram (ug/L) - TW1	1/09/2018	<MDL 1	190.00	No	No
Picloram (ug/L) - TW2A	1/09/2018	<MDL 1	190.00	No	No
Picloram (ug/L) - TW3	1/09/2018	<MDL 1	190.00	No	No
Prometryne (ug/L) - TW1	1/09/2018	<MDL 0.03	1.00	No	No
Prometryne (ug/L) - TW2A	1/09/2018	<MDL 0.03	1.00	No	No
Prometryne (ug/L) - TW3	1/09/2018	<MDL 0.03	1.00	No	No
Simazine (ug/L) - TW1	1/09/2018	<MDL 0.01	10.00	No	No
Simazine (ug/L) - TW2A	1/09/2018	<MDL 0.01	10.00	No	No
Simazine (ug/L) - TW3	1/09/2018	<MDL 0.01	10.00	No	No
Terbufos (ug/L) - TW1	1/09/2018	<MDL 0.01	1.00	No	No
Terbufos (ug/L) - TW2A	1/09/2018	<MDL 0.01	1.00	No	No
Terbufos (ug/L) - TW3	1/09/2018	<MDL 0.01	1.00	No	No
Tetrachloroethylene (ug/L) - TW1	1/09/2018	<MDL 0.35	10.00	No	No
Tetrachloroethylene (ug/L) - TW2A	1/09/2018	<MDL 0.35	10.00	No	No
Tetrachloroethylene (ug/L) - TW3	1/09/2018	<MDL 0.35	10.00	No	No
2,3,4,6-Tetrachlorophenol (ug/L) - TW1	1/09/2018	<MDL 0.20	100.00	No	No
2,3,4,6-Tetrachlorophenol (ug/L) - TW2A	1/09/2018	<MDL 0.20	100.00	No	No
2,3,4,6-Tetrachlorophenol (ug/L) - TW3	1/09/2018	<MDL 0.20	100.00	No	No
Triallate (ug/L) - TW1	1/09/2018	<MDL 0.01	230.00	No	No
Triallate (ug/L) - TW2A	1/09/2018	<MDL 0.01	230.00	No	No
Triallate (ug/L) - TW3	1/09/2018	<MDL 0.01	230.00	No	No

Trichloroethylene (ug/L) - TW1	1/09/2018	<MDL 0.44	50.00	No	No
Trichloroethylene (ug/L) - TW2A	1/09/2018	<MDL 0.44	50.00	No	No
Trichloroethylene (ug/L) - TW3	1/09/2018	<MDL 0.44	50.00	No	No
2,4,6-Trichlorophenol (ug/L) - TW1	1/09/2018	<MDL 0.25	5.00	No	No
2,4,6-Trichlorophenol (ug/L) - TW2A	1/09/2018	<MDL 0.25	5.00	No	No
2,4,6-Trichlorophenol (ug/L) - TW3	1/09/2018	<MDL 0.25	5.00	No	No
Trifluralin (ug/L) - TW1	1/09/2018	<MDL 0.02	45.00	No	No
Trifluralin (ug/L) - TW2A	1/09/2018	<MDL 0.02	45.00	No	No
Trifluralin (ug/L) - TW3	1/09/2018	<MDL 0.02	45.00	No	No
Vinyl Chloride (ug/L) - TW1	1/09/2018	<MDL 0.17	1.00	No	No
Vinyl Chloride (ug/L) - TW2A	1/09/2018	<MDL 0.17	1.00	No	No
Vinyl Chloride (ug/L) - TW3	1/09/2018	<MDL 0.17	1.00	No	No
Trihalomethanes - farthest point in the distribution system (ug/L)	Running average	12.88	100	No	No
HAA's - Haloacetic Acids	Running average	<MDL 5.3	n/a	No	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards. n/a